

No.3373/3-8/TFS/2019
Government of Tripura
Directorate General of Fire Service
Tripura, Agartala.

Dated, Agartala, the 30th, March, 2019

To
The Headmaster,
Dr. B. R. Ambedkar English Model School,
Government of Tripura,
Anandanagar, Sadar,
Tripura West.

Subject:- **Provisional NOC in favour of Dr. B. R. Ambedkar English Model School.**

Sir,


Please refer to your letter No. F.I(3)/HM/DBRAEMS/SDR/2016/426 dated 27/03/2019 on the above cited subject.

It is to inform you that officers of Agartala Fire Station visited in your School on 27/03/2019 and found that Fire Fighting arrangement in your School is inadequate. Therefore, the following instructions have been issued in respect of fire safety of your School based on recommendations of Part -4 NBC of India, 2016.

1. Instructions	
(a)	ABC Fire extinguisher having capacity -4 Kg to be installed at the office room of Headmaster.
(b)	ABC Fire extinguisher having capacity -4 Kg to be installed at computer room and Laboratory one each.
(c)	CO2 fire extinguisher having capacity -4.5 Kg to be installed at electric Main & CO2 fire extinguisher having capacity -2 Kg to be installed sub-main panel board.
(d)	Installed Fire extinguisher at the class room block at the distance of 15 mtrs.
2.	Trained persons are to be engaged for handling equipments of the system while in case of exigency.

It is hereby advised that above instructions are to be complied with 3 months from the receipt of this letter and intimate the OC, Agartala Fire Station about compliance of above mention instructions for verification from our end. Though 3 months are allotted for installation of Fire Fighting equipments, efforts should be made to install the same at the earliest. Final NOC would be issued only after verification of your School by the officer of Fire Service Department on the compliance of our instructions. Meantime, the **Provisional NOC** is hereby issued in favour of your School only with immediately effect.

Yours faithfully,


(Uttam Kr. Bhaumik, IPS)
Joint Director,
For Director General Fire Service,
Tripura, Agartala.

Copy to :-

1. The Divisional Fire Officer, West Division, Agartala for Information.
2. OC, Agartala Fire Station for favour of Information.